Digital Panel Meter **K3TE**

CSM_K3TE_DS_E_1_1

Easy-to-use, Low-cost Digital Panel Meter that Accepts DC Input

- Compact DIN-size (96 x 48 (W x H)) body.
- Mounting thickness of only 3.5 mm required.
- Highly visible display with 14.2-mm-high LEDs.
- Easy-to-mount snap-in construction.
- Conforms to EMC standards EN61010-1 (IEC61010-1).



Model Number Structure

■ Model Number Legend

K3TE -				
	1	2	3	4

1, 2. Input Code

V1: ± 199.9 mV V2: ± 1.999 V V3: ± 19.99 V V4: ± 199.9 V A1: ± 199.9 μ A A2: ± 1.999 mA A3: ± 19.99 mA A4: ± 199.9 mA A5: ± 1.999 A

3. Series No.

1: Current series

4. Supply Voltage

4: 100 to 120 VAC 5: 200 to 240 VAC

6: 24 VDC (internally insulated)

OMRON

Ordering Information

■ List of Models

Range	Measuring ranges	Supply voltage		
		100 to 120 VAC	200 to 240 VAC	24 VDC (internally insulated)
DC voltage	±199.9 mV	K3TE-V114	K3TE-V115	K3TE-V116
	±1.999 V	K3TE-V214	K3TE-V215	K3TE-V216
	±19.99 V	K3TE-V314	K3TE-V315	K3TE-V316
	±199.9 V	K3TE-V414	K3TE-V415	K3TE-V416
DC current	±199.9 μA	K3TE-A114	K3TE-A115	K3TE-A116
	±1.999 mA	K3TE-A214	K3TE-A215	K3TE-A216
	±19.99 mA	K3TE-A314	K3TE-A315	K3TE-A316
	±199.9 mA	K3TE-A414	K3TE-A415	K3TE-A416
	±1.999 mA	K3TE-A514	K3TE-A515	K3TE-A516

Note: The K3TE-V4 $\square\square$ does not conform to CE marking standards.

■ Accessories (Order Separately)

Name	Appearance	Model
Water-resistive Soft Front Cover		K32-L49SC
Water-resistive Mounting Bracket		K32-L49MB

Note: Be sure to use the Soft Front Cover and Mounting Bracket as a set.

OMRON

Specifications

■ Ratings

Supply voltage	100 to 120 VAC; 200 to 240 VAC (50/60 Hz); 24 VDC (internally insulated)				
Operating voltage range	-15% to +10% of supply voltage				
Power consumption	3 VA (at max. AC load); 1.3 W (a	it max. DC load) (se	e note)		
Insulation resistance	10 M Ω min. (at 500 VDC) between	en external terminal	and case		
Dielectric strength	DC model: 500 VDC min. for	The second secon			
Noise immunity	AC model: ±1,500 V on power supply terminals in normal or common mode DC model: ±480 V on power supply terminals in normal mode ±1,500 V on power supply terminals in common mode				
Vibration resistance	Malfunction: 10 to 55 Hz, 0.5-mm single amplitude for 10 min each in X, Y, and Z directions Destruction: 10 to 55 Hz, 0.75-mm single amplitude for 2 hrs each in X, Y, and Z directions				
Shock resistance	Malfunction: 98 m/s² for 3 times each in 6 directions Destruction: 294 m/s² for 3 times each in 6 directions				
Ambient temperature	Operating: -10° to 55°C (with no icing) Storage: -20° to 65°C (with no icing)				
Ambient humidity	Operating: 35% to 85% (with no condensation)				
Ambient operating atmosphere	No corrosive gas				
EMC	(EMI) Emission Enclosure: Emission AC Mains: (EMS) Immunity ESD: Immunity RF-interference: Immunity Fast Transient Noise: Immunity Burst Noise: Immunity Surge: Immunity Conducted Disturbance Immunity Voltage Dip/Interrupting	CISPR 11 Group 1 EN61326+A1 EN61000-4-2: EN61000-4-3: EN61000-4-4: EN61000-4-5: e EN61000-4-6: g EN61000-4-11:	Industry I class A: CISRP16-1/-2 I class A: CISRP16-1/-2 Industry 4 kV contact discharge (level 2) 8 kV air discharge (level 3) 10 V/m (amplitude-modulated, 80 MHz to 1 GHz) (level 3) 2 kV (power line) (level 3) 1 kV line to line (I/O signal line) 1 kV line to line 2 kV line to ground (power line) 3 V (0.15 to 80 MHz) (level 2) 0.5 cycles, 0, 180°, 100% (rated voltage)		
Approved standards	Conforms to EN61326+A1, EN61010-1 (IEC61010-1) Conforms to VDE0106/P100 (finger protection) when the terminal cover is mounted.				

Note: 1. An inrush current of approximately 0.5 A will flow at the moment the power is turned on and continued for approximately 2 ms.

2. The K3TE-V4□□ does not conform to CE marking standards.

■ Characteristics

Input signal	DC voltage/current		
A/D conversion method	Double integral method		
Sampling period	2.5 times/s		
Display refresh period	2.5 times/s		
Max. displayed digits	3 1/2 digits (±1999)		
Display	7-segment red LED		
Decimal point display position	By short-circuiting terminals		
Sign display	"-" is displayed automatically with a negative input signal		
Overflow/underflow display	Overflow: /□□□ Underflow: - /□□□		
Zero suppression	Not supported.		
External control	Process value hold (terminals on rear panel short-circuited)		
Degree of protection	Front panel: IEC IP51 (see note) Case: IEC IP20 Terminals: IEC IP00		

Note: IP51 is maintained when the water-resistive soft cover and bracket are used. IP50 will be, however, maintained without these water-resistive accessories.

OMRON 3

■ Measuring Ranges

Input range	Measuring range	Max. resolution	Input impedance	Accuracy	Max. permissible load
DC voltage	±199.9 mV	100 μV	100 MΩ	±0.1%rdg ±1 digit	±250 V
	±1.999 V	1 mV	100 ΜΩ	±0.1%rdg ±1 digit	±250 V
	±19.99 V	10 mV	10 ΜΩ	±0.1%rdg ±1 digit	±250 V
	±199.9 V	100 mV	10 ΜΩ	±0.1%rdg ±1 digit	±350 V
DC current	±199.9 μA	100 nA	1 kΩ	±0.1%rdg ±1 digit	±10 mA
	±1.999 mA	1 μΑ	100 Ω	±0.1%rdg ±1 digit	±50 mA
	±19.99 mA	10 μΑ	10 Ω	±0.1%rdg ±1 digit	±150 mA
	±199.9 mA	100 μΑ	1 Ω	±0.1%rdg ±1 digit	±500 mA
	±1.999 mA	1 mA	0.1 Ω	±0.3%rdg ±1 digit	±3 A


Note: The above accuracy is at an ambient temperature of 23±5°C.

Connections


■ External Connections

Connector and connector screws are provided with the model.

AC Power Supply




DC Power Supply



Note: 1. Terminals 3 and 7 of the AC and DC models are not internally insulated. Connect a relay with high contact reliability and insulation (with a minimum load current of 0.3 mA) or a photocoupler with high insulation (with a residual voltage of 1 V max. and a current leakage of 0.1 mA max.) to these terminals for external control.

2. The terminals marked with a white rectangular box are not used. Do not use these terminals for transmission of signals.

Nomenclature




Select the decimal position with terminal 12, 13, or 14 on the rear panel.


103 102 101


Dimensions

Note: All units are in millimeters unless otherwise indicated.










Panel Cutouts



Note: The values above are recommended values. Do not group-mount the meters at intervals less than the recommended ones.


LED Indicator Size



Application Examples

High DC Voltage Measurement


When voltage exceeding the maximum voltage in the standard range is measured (for example: more than 200 V), a divider is connected externally.



 $\frac{E2}{E1} = \frac{R2}{R1 + R2}$

Large DC Current Measurement

When large DC current exceeding 2 A is measured, a shunt is connected externally.



When current range DPM is used, disconnect the internal shunt resistor.

Safety Precautions

Mounting

Recommended panel thickness is 1 to 3.2 mm.

When mounting, insert the Digital Panel Meter in the mounting hole and make sure that the Digital Panel Meter is secured with mounting hooks.

Always attach the Mounting Bracket before wiring the terminals. Also, always remove the wiring before removing the Mounting Bracket.

Mount the Digital Panel Meter as horizontally as possible.

Never use the Digital Panel Meter in locations where corrosive gas (particularly sulfide or ammonia gas) is generated.

As much as possible avoid use of the Digital Panel Meter in a location subject to severe shock or vibration, excessive dust, or excessive moisture.

Select a mounting location where the Digital Panel Meter can be used at an ambient operating temperature -10° to 55° C.

No product is shipped with the unit label attached. Select a unit label from the sheet provided, and attach it to the Digital Panel Meter.



Calibration

Calibrate the Digital Panel Meter regularly so that the Digital Panel Meter can maintain processing accuracy.

Use a standard signal generator with an accuracy of 99.99% min. for calibration.


For the precise calibration methods, refer to the Instruction Sheet for the Digital Panel Meter.

After the front panel cover is removed to calibrate the K3TE, be sure not to touch components other than the calibration adjustor. Keep metal objects off the K3TE while calibrating, especially when power is turned on.

Accessories (Order Separately)

Water-resistive Soft Front Cover

Before mounting the Digital Panel Meter to a panel, attach the water-resistive soft front cover and mounting bracket to the Digital Panel Meter properly so that the Digital Panel Meter will maintain IP51 water-resistive standards. Before you calibrate Digital Panel Meters, remove the water-resistive soft front cover. Refer to the operation manual included with the Digital Panel Meter for the calibration procedure.



Note: Be sure to use the Water-resistive Soft Front Cover and mounting bracket together.

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

In the interest of product improvement, specifications are subject to change without notice.